
		<b>CORRIGENDUM # 2</b> <b>SUPPLY, INSTALLATION, TESTING, COMMISSIONING, OPERATION AND MAINTENANCE OF 5 NOS. 1200 SCMH CNG COMPRESSOR PACKAGES</b> <b>TENDER NO. P.005914 R11050 007</b>		<b>Date: 24.04.2017</b>
<b>Project: City Gas Distribution Project in Agra</b>				
<b>Owner: Green Gas Ltd. (GGL)</b>				
Sr. No.	Description	Tender Page No.	Clause/ Para/ Section	Amendment/Addition/Modification/Deletion
Vol I of II				
Vol II of II				
1	Basic Design	200022	4.0/4.1.3/-	Please read the clause as "Suction line pressure may vary from 14 kg/cm <sup>2</sup> G to 19 kg/cm <sup>2</sup> G with discharge pressure at 255 kg/cm <sup>2</sup> G. A suction pressure regulator shall be installed to limit the suction pressure to 19 kg/cm <sup>2</sup> G. The suction pressure of 16 kg/cm <sup>2</sup> G shall be used for compressor sizing/ selection"
<b>Note: All other terms &amp; conditions of tender document remain unaltered.</b>				

  
 Rajeev  
 24/04/17

  
 SK Gupta  
 26/4/17

